

Smoke control test chamber – Dimensions (W x H): 5 m x 5 m, additional standard sizes 4,0 m x 4,0 m and 3,4 m x 3,4 m

DIN EN 1634-3 : 2009-09 (European)

Fire resistance tests for door and shutter assemblies – Part 3: Smoke control doors and shutters. Test for determination of leakage rate.

DIN 18095-2 : 1991-03 (national)

Smoke control doors; type testing for durability and leakage. Test for determination of leakage rate.



Chamber for smoke leakage tests 5 x 5 m – interior view



Chamber for smoke leakage tests 5 x 5 m – front view; example for reduction in size to 3,4 x 3,4 m



Chamber for smoke leakage tests 5 x 5 m – side view

DMT GmbH & Co. KG

Anlagen- und Produktsicherheit

Prüflaboratorium für Brandschutz

Tremoniastraße 13

44137 Dortmund

Germany

Tel +49 231-5333-240

Fax +49 231-5333-299

www.dmt-group.com · dmt-firetest@dm-group.com

www.dmt.de



TÜV NORD GROUP

Earth. Insight. Values.